

**EU Declaration of Conformity**

issued under the sole responsibility of the manufacturer

The object of this declaration: Electropneumatic positioners **APIS-XXX-...-RSt...**,  
**APIS-XXX-...-REx...**, **APIS-XXX-...-RSt...-IHx...** and **APIS-XXX-...-REx...-IHx...**

Manufacturer: **APLISENS S.A.**,  
**ul. Morelowa 7,**  
**03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Electropneumatic positioners **APIS-XXX-...-RSt...**, **APIS-XXX-...-REx...**,  
**APIS-XXX-...-RSt...-IHx...** and **APIS-XXX-...-REx...-IHx...** in all versions comply with directives:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A.

The following standard was applied EN 61326-1:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN 50581:2012.

Electropneumatic positioners **APIS-XXX-...-REx...** and **APIS-XXX-...-REx...-IHx...** in intrinsically safe versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Electropneumatic positioners **APIS-XXX-...-REx...** in intrinsically safe versions are marked with the following certificate marking:

Certificate no. II 2G Ex ia IIC T6/T5 Gb  
FTZÚ 10 ATEX0093

Certificate (Module B) was issued by Notified Body no.1026, Physical Technical Testing Institute, Pikartska 7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2012, EN 60079-11:2012.

Electropneumatic positioners **APIS-XXX-...-REx...-IHx...** in intrinsically safe versions are marked with the following certificate marking:

Certificate no. II 2G Ex ia IIC T5/T6 Gb  
KDB 17 ATEX0035

Certificate (Module B) was issued by Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-11:2012.

Notification of quality assurance is issued (Module D) by Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Electropneumatic positioners **APIS-XXX-...-RSt...**, **APIS-XXX-...-REx...**,  
**APIS-XXX-...-RSt...-IHx...** and **APIS-XXX-...-REx...-IHx...** comply with standards:  
EN 61514:2002, EN 61514-2:2004.

Warsaw, 21.07.2017

Adam Żurawski  
General Manager

